

Dansand A/S

Lervejdal 8b – 8740 Brædstrup

Tlf. +45 8682 5811


E-mail: info@dansand.dk**Filtersand 0****0,4 – 0,8 mm**

Specifications:

Filtersand Type I

General characteristics	Method	Typical value	Range
Bulk density . Kg/m ³	EN 12902	1586	1530-1620
Disparity - D60/D10	EN 12902	1,3	<1,5

Sieve size - mm	1	0,9	0,8	0,71	0,63	0,5	0,4	0,355	0,315	0,25	0,125	0,063
Passing - weight WT%	100	99,6	96,3	86,1	63,8	9,7	1,1	0,5	0,3	0,0	0,0	0,0



Chemical analysis						
Type	Fe ₂ O ₃	Al ₂ O ₃	K ₂ O	CaO	Na ₂ O	SiO ₂
Weight WT%	0,117	0,805	0,365	0,068	0,15	98,11

Supplier declaration:

DANSAND A/S Declares that the materials above meets the requirements of the argreement of EN 12904:2005

Responsible: QHSE Manager Morten Grundvad